



## Analysis Of Clean Water Production Capacity Regional Drinking Water Company City Tidore Islands

Tamrin Husaen

Faculty of Engineering, University of Nuku Tidore

### Abstract

Received: 15 Februari 2023

Revised: 24 Februari 2023

Accepted: 4 Maret 2023

*The need for clean water is an unlimited and sustainable need, while the need for clean water supply and services is increasing from time to time which is sometimes not matched by service capabilities. This is a challenge that must be faced by the local government and a solution is immediately sought so that the majority of people who depend on PDAMs in the city of Tidore Islands do not lack clean water. The purpose of this study was to determine the prediction of the clean water needs of the population of the city of Tidore Islands in the next 20 years, starting from 2016 to 2036. This research was carried out in the service area of the PDAM, Tidore Islands district, especially on Tidore Island. Prediction of population growth and increasing facilities Social activities are carried out using Arithmetic and Geometric methods. The results of this study indicate that the need for clean water for the people of the city of Tidore Islands in 2036 is for normal use of 488.20 liters/second, for maximum day use is 572.90 liters/second. for use at peak hours of 871.8 liters / second.*

**Keywords:** Production capacity, clean water.

(\*) Corresponding Author: [alampatra70@gmail.com](mailto:alampatra70@gmail.com)

**How to Cite:** Husaen, T. (2023). Analysis Of Clean Water Production Capacity Regional Drinking Water Company City Tidore Islands. *Jurnal Ilmiah Wahana Pendidikan*, 9(7), 449-466. <https://doi.org/10.5281/zenodo.7825870>

## INTRODUCTION

Water is a basic need that is very basic for human survival, so there is an expression "Where there is water there is life". People can live without food for three weeks, but without drinking water, humans can only survive for 4-7 days. The availability of clean water is very important for household and industrial consumption. Thus, clean water gets the main handling priority because it involves the livelihood of many people. Meeting the need for clean water can be done in various ways, adapted to existing resources. For urban areas, in general, the provision of clean water is piped and non-piped. Regional drinking water company (PDAM) as the manager of drinking water with a piped system, while the non-pipeline system is managed by the community. The need for clean water is an unlimited and sustainable need. Meanwhile, the need for clean water supply and service is increasing from time to time, which is sometimes not matched by service capability. This increase in demand is caused by an increase in the population, an increase in the standard of living of the residents as well as the development of the city/service area or other matters related to the improvement of the socio-economic conditions of the residents.

The population of the island city of Tidore has increased every year where in 2015 it reached 96,979 people, in 2016 it reached 98,206 people, in 2017 it reached 99,337 people, in 2018 it reached 100,415 people, in 2019 it reached 101,414 people and in 2020 it reached 114,480. This is a challenge that must be



faced by the local government and a solution must be found immediately so that the majority of people who depend on PDAMs in the city of Tidore Islands do not lack clean water. If this condition is not immediately addressed, the water demand will continue to increase along with the increase in population each year.

Several previous research results revealed that by calculating the clean water capacity analysis, it will produce a projection of service coverage so that clean water services can be achieved, Meanwhile, the results of research conducted by show that the influence of community intervention factors (eg the use of water-saving equipment and rainwater tanks) on water needs is among the most significant. The results also confirm that community intervention programs and water pricing policies together can play a significant role in reducing overall water demand. On the other hand, the effect of rainfall on water demand was found to be very limited, while temperature showed some degree of correlation with water demand.

Other researchers reveal that the influence of society and government, will cause the proposed multi-criteria model decision-making approach to be appropriate for carrying out strong and well-structured decision-making. In balancing the water supply-demand strategy in the water supply system and the research results of highlight the need for water resource planners and decision makers to better consider the importance of effective public awareness and education, encouraged internal and external, in the behavior and management of water demand.

In general, the source of raw water on Tidore Island is ground water, where for the PDAM's raw water source, drilled wells are used, the depth varies between 5 - 100 meters. The obstacle faced in the future is the limited discharge produced by each well while the increase in the amount of clean water demand cannot be avoided. Lack of water at certain hours, especially at peak hours of use, can disrupt the water demand for the needs of the population, thus requiring alternative regulators and an effective increase in water production capacity that meets minimum needs at peak hours.

Based on this, the problem in this study is how much water production capacity is needed to meet the use of clean water for the community in the city of Tidore Islands?

The purpose of this study was to analyze the clean water production capacity of PDAM Tidore Kepulauan City.

## **METODE**

This research was conducted in the service area of PDAM Tidore Kepulauan City with a duration of six months. The research design uses quantitative descriptive research to predict the need for clean water in the next 20 years. The type of data used is secondary data in the form of time series of customers' clean water usage in the City of Tidore Islands for 12 years, starting from 2004 until 2016.

The data processing technique is to analyze the clean water production capacity of PDAM Tidore Islands using the Geometrical Increase method and the Arithmetical Increase method.

Geometrical Increase method

$$P_n = P_o(1+r)^n \quad (1)$$

with :

$P_n$  = Total population in the nth year (people)  
 $P_o$  = Total population at the beginning of the year (people)  
 $r$  = Percentage of population geometrical growth per year (%)  
 $n$  = Period of time under review (years)

Arithmetical Increase method.

$$P_n = P_o + n.r \quad (2)$$

$$r = \frac{P_t - P_o}{t} \quad (3)$$

with :

$P_n$  = Total population in the nth year (people)

$P_o$  = Total population at the beginning of the projection year (people)

$r$  = Population growth rate per year (%)

$n$  = Period of time under review (years)

$t$  = Number of years before the year of analysis

## RESULTS AND DISCUSSION

### Geographical Circumstances

Tidore Islands City as an autonomous region which was divided from the Central Halmahera district based on Law no. 1 of 2003 concerning regional expansion which was inaugurated on May 31, 2003. As for the map of the city of Tidore, the islands are:



**Figure 1.** Map of the City of Tidore Islands

Geographically, the location of the Tidore Archipelago City area is at the astronomical limit of 00 - 20 north latitude at north latitude to 00-500 south latitude and at 127010'-127045' east longitude. Tidore Archipelago City has a land area of 1,550.37 km<sup>2</sup>. The entire area in this area is surrounded by the sea and has the following boundaries:

- North side with West Halmahera Regency
- South side with South Halmahera Regency
- East side with East Halmahera Regency and Central Halmahera Regency
- West side with the City of Ternate

### Area and Topography

The administrative area of Tidore Kepulauan City is divided into 89 villages/kelurahan, with an area of 1,883.33 square kilometers or equal to 3.01%

of the North Maluku Province. Furthermore, the following table is a breakdown of the area of the administrative area of the Region by District in the City of Tidore, Islands:

**Table 1.** Area by District in the City of Tidore, Islands

Name of District	Area (Km) <sup>2</sup>	Percentage (%)
South Tidore	42.4	2.73
North Tidore	37.64	2.43
Tidore	36.08	2.33
East Tidore	34	2.19
Oba	403.67	26.04
South Oba	196.58	12.68
North Oba	376	24.25
Central Oba	424	27.35

Source: BPS City of Tidore Islands

From the total area owned by Tidore Kepulauan City, most of them are highlands, which is 72.5% of the total area and the rest is lowlands as much as 27.74%. There are 5 sub-districts whose topography is highland and hilly, namely South Oba, Tidore, South Tidore, Central Oba, East Tidore, while the other sub-districts are in the lowlands.

**Table 2.** Area Height Above Sea Level (ASL) According to Observations in the City of Tidore, Islands

Name of District	High ASL
South Tidore	22
North Tidore	18
Tidore	31
East Tidore	14
Oba	26
South Oba	28
North Oba	48
Central Oba	20

Source: BPS City of Tidore Islands

### Climate

The climate in the Tidore Archipelago City area is like a tropical island area, where the climate is strongly influenced by sea breezes. The dry season occurs from December to March, while the rainy season occurs from May to October caused by the southeast wind. The transition season occurs in April and December.

**Table 3.** Average Monthly Rainfall and Rainfall in the City of Tidore Islands

Month	Rainy Day (Day)	Dry Days (Days)	Rainfall (mm <sup>3</sup> )
-------	--------------------	--------------------	--------------------------------

January	11	20	106
February	1	28	38
March	8	23	204
April	16	14	111
May	13	18	238
June	20	10	344
July	19	12	224
August	7	24	139
September	11	19	248
October	21	10	339
November	17	13	179
December	18	13	280
Total	162	204	2 450

Source : Soasio Plant Protection Brigade

### Hydrological Conditions

In general, the availability of clean water on the island of Tidore is experiencing difficulties, especially during the dry season. In coastal areas that are not served by PDAM, clean water is obtained from residents' dug wells. In the dry season, this well experiences a decrease in water flow and feels a bit brackish. This dug well can serve 30 families. In the rainy season, in general, the people of the city of Tidore Islands use water by collecting rainwater in a reservoir.

Surface water sources in the Tidore Islands city area are on the island of Halmahera, which include the Kayasa river, Akelamo river, Neweri river, Sinofa river, Tafaga river, and Lifofa river. Meanwhile, the rivers in the Tidore island area do not have a continuous water discharge.

### Demographics

The population of the city of Tidore Islands in 2016 was 98,206 people, consisting of 49,552 men and 48,695 women. Judging from the population distribution in each sub-district, Tidore sub-district has the most population with a population of 18,801 people and the sub-district with the least population is Oba Selatan sub-district, which is 5,476 people. For the population density of each sub-district, Tidore sub-district has the highest density with a total of 521 people per square kilometer, then North Tidore sub-district with a total of 393 people per square kilometer and the lowest is Oba Tengah sub-district with a total of 22 people per square kilometer.

**Table 4.** Area and Total Population by District in Tidore Islands City

Name of District	Area (Km) <sup>2</sup>	Total Population (Persons)	Population density
South Tidore	42.4	13 338	315
North Tidore	37.64	14 809	393
Tidore	36.08	18 801	521
East Tidore	34	8 367	246
Oba	403.67	11 431	28
South Oba	196.58	5476	28
North Oba	376	16473	44

North Oba	<b>376</b>	<b>16473</b>	<b>44</b>
Central Oba	424	9511	22
	1.550,37	98.206	63

Source: BPS City of Tidore Islands

### 1.1. Production Capacity and Existing Service Level of PDAM Tidore Kepulauan City

The production capacity of PDAM Tidore Islands is 39.2 L/sec. With details on the table:

**Table 5. Production Capacity of PDAM Tidore Islands**

No	SP	W	IMPLEMENTATION	Installed capacity	Production capacity	Household Connections (UNIT)	DESCRIPTION
AM UNITS	ATER SOURCE		Year of Development of Source of funds				
In	D	1	A	3	2	29	6 Units of Wells and 1 Unit of Bron capturing
donesiana	Deep Well	985 s/d 2014	PBN	5,538 Ltr/s	4.2 Ltr/s	38	
Gu	D	2	A	4	4	11	1 Well Unit
rabati	Deep Well	017	PBD	,7 Ltr/s	Ltr/s	24	
M	D	2	A	4	4	52	1 Well Unit
areku	Deep Well	012	PBD	,7 Ltr/s	Ltr/s	9	
Fo	D	2	A	4	4	13	2 Units of Wells (1 unit in use)
baharu	Deep Well	014	PBN	,7 Ltr/s	Ltr/s	5	
Ru	D	2	A	3	3	31	1 Well Unit
m	Deep Well	013	PBN	,8 Ltr/s	Ltr/s	0	
Total Production Capacity				3		0	
				9,2 Ltr/s			

Source: PDAM Tidore Islands

Currently, there are three sub-districts in the Tidore Islands City district that have been served with clean water from PDAM, namely, Tidore sub-district, South Tidore sub-district, and North Tidore sub-district. The sub-districts of East Tidore, Oba, South Oba, North Oba, Central Oba have not been served. From data on clean water services in North Maluku Province in 2016, the level of service from PDAM Tidore Islands is 4,383, public hydrants 9 units of non-domestic commercial connections, population served 21,915 people, service percentage 22, 31% of the total population of the city of Tidore Islands.

### Population Growth Analysis

For the accuracy of the calculation of the estimated population in the next few years, a rather large sample of the population is needed, the more sample years that are calculated, the more accurate the calculation results and closer to the predictions set. This study uses a sample of population growth from 2004 to 2016. Using the Geometric and Arithmetic method, the population growth ratio is calculated which is then averaged to project population growth in the next 10 years.

Table 6. Population Growth Data for Tidore Islands City

No	Year	Number of Souls	Arithmetic Growth (Soul)	Geometric Growth (%)
----	------	-----------------	--------------------------	----------------------

1	2004	49474		
			726	1.45
2	2005	50200		
			500	1
3	2006	51300		
			600	1.16
4	2007	51900		
			600	1.14
5	2008	52655		
			755	1.4
6	2009	53836		
			1181	2.14
7	2010	55133		
			1297	2.25
8	2011	57651		
			2518	4.3
9	2012	58804		
			1153	1.7
10	2013	68654		
			9850	12.55
11	2014	78504		
			9850	11.15
12	2015	88354		
			9852	10
13	2016	98206		

Source: Data Processing Results

#### Population Projection Calculation

##### *Geometrical Increase method*

The basic formula for the geometric method:

$$P_n = P_o(1+r)^n$$

From the data in table (6),  $P_o = 98206$  souls

$$r = 4.44\% \text{ or } = 0.044$$

so the forward projection equation is:

$$P_n = 98206(1+0.044)^n \quad (3)$$

##### *Arithmetical Increase method*

The formula for the Arithmetic method is:

$$P_n = P_o + nr \quad (4)$$

$$r = \frac{P_o - P_t}{t}$$

$$t = T_o - T_t$$

$P_t$  = Total Population in 2004 = 49474 people

$P_o$  = Total Population in 2016 = 98206 people

$T_o$  = 2016

$T_t$  = 2004

$$r = \frac{(98206 - 49474)}{2016 - 2004}$$

$$r = \frac{48732}{11} = 4430$$

So the arithmetic equation is:

$$P_n = P_0 + nr$$

$$P_n = 98206 + 4430n \quad (5)$$

**Table 7. Population Projection of Tidore Islands City 2016-2036**

Year	Arithmetic Method $P_n = 98206 + 4430n$	Geometric Method $P_n = 98206(1+0,044)^n$	Average projection
2016	98206	98206	98206
2017	102636	102527	102582
2018	107066	107038	107052
2019	111496	111748	111722
2020	115926	116665	116695
2021	120356	121798	121777
2022	124786	127157	127172
2023	129216	132752	132784
2024	133646	138593	138520
2025	138076	144691	144684
2026	142506	151058	151082
2027	146936	157704	157720
2028	146936	164643	164690
2029	146936	171888	171888
2030	146936	179451	179451
2031	146936	187346	187346
2032	146936	195590	195590
2033	146936	204229	204229
2034	146936	213276	213276
2035	146936	222750	222750
2036	146936	232640	232640

Source: Data Processing Results

From the analysis of the data above, the population of Tidore Islands City in 2016-2036 is 221,088 people (20 years projection).

#### 1.1.1. Standards of Analysis

According to the planning criteria for the 2017 Directorate General of Human Settlements, the Public Works Department, the standards for clean water requirements are as follows:

1. Consumption of household connections: 120 liters/person/day
2. Consumption of general hydrants is: 60 liters/person/day
3. The comparison between household connections and public hydrants is: SR = HU = 80: 20

### Clean Water Needs Analysis

Domestic Sector

*Household Connection*

**Table 8. Household Water Needs**

o	ear	Y	Number of Population (people)	Service Level (%)	Number of Serviced (lives)	Average water consumption (liters/person/day)	Total Usage (liters/day)	Amount of Water Needs (Liters/second)	
		b	c	d	e	f	g	h	
016	2	06	982	0	565	78	120	27776	109.1
017	2	582	102	0	665	82	120	47827	114.0
018	2	052	107	0	642	85	120	277004	118.9
019	2	111	622	0	298	89	120	715709	124.0
020	2	295	116	0	36	93	120	164361	129.2
021	2	077	121	0	862	96	120	623397	134.5
022	2	125	972	0	777	10	120	93274	140.0
023	2	130	984	0	4787	10	120	574470	145.5
024	2	136	120	0	8996	10	120	667483	151.2
025	2	141	384	0	3107	11	120	572832	157.1
026	2	146	782	0	7425	11	120	991060	163.1
027	2	150	754	0	603	12	120	472344	167.5
028	2	155	605	0	4484	12	120	938110	172.9
029	2	160	457	0	8366	12	120	403877	178.3
030	2	165	309	0	2247	13	120	869643	183.7
031	2	170	161	0	6128	13	120	335410	189.1
032	2	175	012	0	0010	14	120	801176	194.5
033	2	179	864	0	3891	14	120	266943	199.8
034	2	184	716	0	7773	14	120	732709	205.2
035	2	189	567	0	1654	15	120	198475	210.6
036	2	194	419	0	5535	15	120	664242	216.0

Source: Data Processing Results

- [a] = serial number
- [b] = Projection Year (Planning Year)
- [c] = Result of calculation of population projection (table 7)
- [d] = Criteria for the Directorate General of Human Settlements = 80%
- [e] = [c] x [d]
- [f] = Planning criteria for the Directorate General of PU
- [g] = [e] x [f]
- [h] = [g]/(24x60x60)

*General Hydrant*

**Table 9. General Hydrant Water Needs**

- [a] = serial number
- [b] = Projection Year (Planning Year)
- [c] = Result of calculation of population projection (table 7)
- [d] = Criteria for the Directorate General of Human Settlements = 80%
- [e] = [c] x [d]
- [f] = Planning criteria for the Directorate General of PU
- [g] = [e] x [f]
- [h] = [g]/(24x60x60)

*General Hydrant*

**Table 9. General Hydrant Water Needs**

No	Year	Number of Population (people)	Service Level (%)	Number of Serviced (lives)	Average water consumption (liters/person/day)	Total Usage (liters/day)	Amount of Water Needs (Liters/second)
	b	c	d	e	f	g	h
016	2	982	0	641	60	78472	13.6
017	2	102	0	20	60	12	14.2
018	2	582	0	516	60	30978	14.9
019	2	107	0	21	60	12	15.5
020	2	052	0	410	60	84626	16.2
021	2	111	0	22	60	13	16.8
022	2	622	0	324	60	39464	17.5
023	2	116	0	23	60	13	18.2
024	2	295	0	259	60	95545	18.9
025	2	121	0	24	60	14	19.6
026	2	077	0	215	60	52925	20.4
027	2	125	0	25	60	15	20.9
028	2	972	0	194	60	11659	21.6
029	2	130	0	26	60	15	22.3
030	2	984	0	197	60	71809	23.0
031	2	136	0	27	60	16	23.6
032	2	120	0	224	60	33435	24.3
033	2	141	0	28	60	16	25.0
034	2	384	0	277	60	96604	25.7
035	2	146	0	29	60	17	26.3
036	2	782	0	356	60	61382	27.0
037	2	150	0	30	60	18	
038	2	754	0	151	60	09043	
039	2	155	0	31	60	18	21.6
040	2	605	0	121	60	67264	22.3
041	2	160	0	32	60	19	23.0
042	2	457	0	091	60	25485	23.6
043	2	165	0	33	60	19	24.3
044	2	309	0	062	60	83705	25.0
045	2	170	0	34	60	20	25.7
046	2	161	0	032	60	41926	26.3
047	2	175	0	35	60	21	27.0
048	2	012	0	002	60	00147	
049	2	179	0	35	60	21	21.6
050	2	864	0	973	60	58368	22.3
051	2	184	0	36	60	22	23.0
052	2	716	0	943	60	16589	23.6
053	2	189	0	37	60	22	24.3
054	2	567	0	913	60	74809	25.0
055	2	194	0	38	60	23	25.7
056	2	419	0	884	60	33030	26.3
057	2		0		60		27.0

Source: Data Processing Results

[a] = serial number

[b] = Projection Year (Planning Year)

[c] = Result of calculation of population projection (table 7)

[d] = Criteria for the Directorate General of Human Settlements = 80%

[e] = [c] x [d]

[f] = Planning criteria for the Directorate General of PU

[g] = [e] x [f]

[h] = [g]/(24x60x60)

**Table 10. Water Needs for Educational Facilities**

No	Year	Number of students (people)	Average consumption(SR) (Liters/second)	Average consumption(HU) (Liters/second)	Total Domestic Water (Liters/second)	15%= 0,15 Domestic water needs
a	b	c	d	e	f	g

<b>1</b>	2016	5	109.12	13.6	122.8	1
		0083				8.4
<b>2</b>	2017	5	113.98	14.2	128.2	1
		2287				9.2
<b>3</b>	2018	5	118.95	14.9	133.8	2
		4587				0.1
<b>4</b>	2019	5	124.02	15.5	139.5	2
		6989				0.9
<b>2</b>	<b>569</b>	<b>124.02</b>	<b>15.5</b>	<b>139.5</b>	<b>20.</b>	
<b>019</b>	<b>89</b>				<b>9</b>	
<b>2</b>	594	129.22	16.2	145.4	21.	
<b>020</b>	97				8	
<b>2</b>	621	134.53	16.8	151.3	22.	
<b>021</b>	14				7	
<b>2</b>	648	139.97	17.5	157.5	23.	
<b>022</b>	48				6	
<b>2</b>	677	145.54	18.2	163.7	24.	
<b>023</b>	01				6	
<b>2</b>	706	151.24	18.9	170.1	25.	
<b>024</b>	80				5	
<b>2</b>	737	157.09	19.6	176.7	26.	
<b>025</b>	90				5	
<b>2</b>	770	163.09	20.4	183.5	27.	
<b>026</b>	36				5	
<b>2</b>	788	167.50	20.9	188.4	28.	
<b>027</b>	28				3	
<b>2</b>	815	172.89	21.6	194.5	29.	
<b>028</b>	17				2	
<b>2</b>	842	178.29	22.3	200.6	30.	
<b>029</b>	07				1	
<b>2</b>	868	183.68	23.0	206.6	31.	
<b>030</b>	96				0	
<b>2</b>	895	189.07	23.6	212.7	31.	
<b>031</b>	85				9	
<b>2</b>	922	194.46	24.3	218.8	32.	
<b>032</b>	75				8	
<b>2</b>	949	199.85	25.0	224.8	33.	
<b>033</b>	64				7	
<b>2</b>	976	205.24	25.7	230.9	34.	
<b>034</b>	54				6	
<b>2</b>	100	210.63	26.3	237.0	35.	
<b>035</b>	343				5	
<b>2</b>	103	216.02	27.0	243.0	36.	
<b>036</b>	032				5	

Source: Data Processing Results

[a] = Sequence Number

[b] = Projection Year (planning year)

[c] = The number of students in 2016 is 50083 people obtained from the BPS City of Tidore Islands in 2017. The calculation of the projected number of students is calculated using the geometric method [d] = Total (SR)

[e] = Total (HU)

[f] = [d]+[e]

[g] = [f] x 15 % The growth of worship facilities is assumed to be equal to population growth. In the regulations set by the Directorate General of Human Settlements Dep. PU, water needs for mosques are 3000 liters/unit/day while for Musallah 2000 liters/unit/day. The projected number is *assumed for the mosque every 5 years to increase by 1 unit*, while the Mushollah increases by 1 unit every 2 year

**Table 11. Water Needs for Mosques**

No	Year	Number of Mosques (Unit)	15%= 0.15 Domestic water demand
a	b	c	d
0	016	2	18.4
1	017	2	19.2
2	018	2	20.1
3	019	2	20.9
4	020	2	21.8
5	021	2	22.7
6	022	2	23.6
7	023	2	24.6
8	024	2	25.5
9	025	2	26.5
10	026	3	27.5
11	027	3	28.3
12	028	3	29.2
13	029	3	30.1
14	030	3	31.0
15	031	3	31.9
16	032	3	32.8
17	033	3	33.7
18	034	3	34.6

Source: Data Processing Result

[a] = Sequence Number

[b] = Projection Year (planning year)

[c] = Number of mosques in 2016 which is 148 people obtained from BPS City of Tidore Islands in 2017. The calculation of the projected number of mosques is calculated with the assumption that in 5 years there will be an increase of 1 mosque.

[d] = 15% of the total domestic water demand.

**Table 12. Water Needs for Mushola Worship Facilities**

No	Year	Number of Mosques (Unit)	15%= 0.15 Domestic water demand
a	b	c	d
1	2016	124	18.4
2	2017	124	19.2
3	2018	125	20.1
4	2019	125	20.9
5	2020	126	21.8
6	2021	126	22.7

7	2022	127	23.6
8	2023	127	24.6
9	2024	128	25.5
10	2025	128	26.5
11	2026	129	27.5
12	2027	129	28.3
13	2028	130	29.2
14	2029	130	30.1
15	2030	131	31.0
16	2031	131	31.9
17	2032	132	2.8
18	2033	132	33.7
19	2034	133	34.6
20	2035	133	35.5
21	2036	134	36.5

Source: Data Processing Result

### *Market Facilities*

Market facilities in the Tidore Islands City area along with the market area can be seen in the following table 12

**Table 14.** Market Area in Tidore City, Islands

No	Market	Market Area (ha)
1	Sarimalaha	4
2	Pasar baru	3
3	PPI Goto	3
4	Rum	2
5	Galala	2
6	Ake Tobololo	2
7	Lola	1
8	Wama	1
Total Land Area		<b>18</b>

To fulfill the need for clean water at market facilities based on the criteria of the Directorate General of Human Settlements, the amount is 1200 liters/ha/day. Meanwhile, the market area is assumed to increase by 2ha every 5 years. The results of the analysis for the need for clean water can be seen in table 15 the following :

**Table 15.** Water Needs for Market facilities

No	Year	Number of Mosques (Unit)	15%= 0.15 Domestic water demand
a	b	c	d
1	2016	124	18.4
2	2017	124	19.2
3	2018	125	20.1
4	2019	125	20.9
5	2020	126	21.8

6	2021	126	22.7
7	2022	127	23.6
8	2023	127	24.6
9	2024	128	25.5
10	2025	128	26.5
11	2026	129	27.5
12	2027	129	28.3
13	2028	130	29.2
14	2029	130	30.1
15	2030	131	31.0
16	2031	131	31.9
<hr/>			
12	2027	129	28.3
13	2028	130	29.2
14	2029	130	30.1
15	2030	131	31.0
16	2031	131	31.9
17	2032	132	32.8
18	2033	132	33.7
19	2034	133	34.6
20	2035	133	35.5
21	2036	134	36.5

Source: Data Processing Result

### *Hospital Facilities*

The development of health facilities until 2016 the number of beds (bed) as many as 250 beds (BPS City of Tidore Islands in Figures 2017). It is assumed that 10 beds are added every 2 years. According to the standard planning criteria from the Directorate General of Human Settlements, the need for public facilities is 10%-15% of the total domestic water demand.

**Table 17.** Water Needs for Hospital Facilities

No	Year	Number of beds (units)	15%= 0.15 Domestic water demand
a		C	d
1	016	24	18.4
2	017	24	19.2
3	018	25	20.1
4	019	25	20.9
5		1	21.8

	020	26	
<b>6</b>		1	22.7
	021	26	
<b>7</b>		1	23.6
	022	27	
<b>8</b>		1	24.6
	023	27	
<b>9</b>		1	25.5
	024	28	
<b>10</b>		1	26.5
	025	28	
<b>11</b>		1	27.5
	026	29	
<b>12</b>		1	28.3
	027	29	
<b>13</b>		1	29.2
	028	30	
<b>14</b>		1	30.1
	029	30	
<b>15</b>		1	31.0
	030	31	
<b>16</b>		1	31.9
	031	31	
<b>17</b>		1	32.8
	032	32	
<b>18</b>		1	33.7
	033	32	
<b>19</b>		1	34.6
	034	33	
<b>20</b>		1	35.5
	035	33	
<b>21</b>		1	36.5
	036	34	

**Source: Data Processing Result**

#### *Health Center Facilities*

There are 10 Puskesmas facilities in the Tidore Islands city area (BPS, Tidore Islands in Figures 2017). Water needs for health centers according to the Directorate General of Human Settlements Dep. PU. the need for public facilities is 10%-15% of the total domestic water demand. It is assumed that in the next ten years there will be an increase of 4 Puskesmas units.

**Table 18.** Water Needs for Health Center Facilities

No	Year	Number of beds (units)	15%= 0.15 Domestic water demand
a	b	C	d
<b>1</b>	2016	124	18.4
<b>2</b>	2017	124	19.2
<b>3</b>	2018	125	20.1

	4	2019	125	20.9	
		020	6	12	21.8
		021	6	12	22.7
		022	7	12	23.6
		023	7	12	24.6
		024	8	12	25.5
0		025	8	12	26.5
1		026	9	12	27.5
2		027	9	12	28.3
3		028	0	13	29.2
4		029	0	13	30.1
5		030	1	13	31.0
6		031	1	13	31.9
7		032	2	13	32.8
8		033	2	13	33.7
9		034	3	13	34.6
0		035	3	13	35.5
1		036	4	13	36.5

### *Health Center Facilities*

There are 10 Puskesmas facilities in the Tidore Islands city area (BPS, Tidore Islands in Figures 2017). Water needs for health centers according to the Directorate General of Human Settlements Dep. PU. the need for public facilities is 10%-15% of the total domestic water demand. It is assumed that in the next ten years there will be an increase of 4 Puskesmas units.

**Table 18.** Water Needs for Health Center Facilities

No	Year	Number of beds (units)	15%= 0.15 Domestic water demand
a	b	C	d
1	2016	124	18.4
2	2017	124	19.2
3	2018	125	20.1
4	2019	125	20.9
<b>2020</b>		<b>126</b>	<b>21.8</b>
2021		126	22.7
2022		127	23.6
2023		127	24.6
2024		128	25.5
2025		128	26.5
2026		129	27.5
2027		129	28.3
2028		130	29.2
2029		130	30.1
2030		131	31.0
2031		131	31.9
2032		132	32.8
2033		132	33.7
2034		133	34.6
2035		133	35.5
2036		134	36.5

### Recapitulation of Clean Water Needs for Tidore Islands City

From the results of calculating the need for clean water in the Tidore Islands City area, the recapitulation results are obtained in table 19.

Table 19. Recapitulation of Clean Water Needs for Tidore Islands City

N	Year	SR	HU	Education facility	Mosque	Mushollah	Market	Office	Hospital	Public health center	Amount				
		(L/s)	(L/s)	(L/s)	(L/s)	(L/s)	(L/s)	(L/s)	(L/s)	(L/s)	(L/s)	(L/s)			
1	016	09.1	1	3.6	1	18.4	1	18.4	8.4	1	8.4	1	8.4	4	51.7
2	017	14.0	1	4.2	1	19.2	1	19.2	9.2	1	9.2	1	9.2	9.2	62.9
3	018	18.9	1	4.9	1	20.1	2	20.1	0.1	2	0.1	2	0.1	0.1	74.3
4	019	24.0	1	5.5	1	20.9	2	20.9	0.9	2	0.9	2	0.9	0.9	86.0
5	020	29.2	1	6.2	1	21.8	2	21.8	1.8	2	1.8	2	1.8	1.8	98.0
6	021	34.5	1	6.8	1	22.7	2	22.7	2.7	2	2.7	2	2.7	2.7	10.3
7	022	40.0	1	7.5	1	23.6	2	23.6	3.6	2	3.6	2	3.6	3.6	22.8
8	023	45.5	1	8.2	1	24.6	2	24.6	4.6	2	4.6	2	4.6	4.6	35.6
9	024	51.2	1	8.9	1	25.5	2	25.5	5.5	2	5.5	2	5.5	5.5	48.8
10	025	57.1	1	9.6	1	26.5	2	26.5	6.5	2	6.5	2	6.5	6.5	62.3
11	026	63.1	1	0.4	2	27.5	2	27.5	7.5	2	7.5	2	7.5	7.5	76.1
12	027	67.5	1	0.9	2	28.3	2	28.3	8.3	2	8.3	2	8.3	8.3	86.3
13	028	72.9	1	1.6	2	29.2	2	29.2	9.2	2	9.2	2	9.2	9.2	98.7
14	029	78.3	1	2.3	2	30.1	3	30.1	0.1	3	0.1	3	0.1	0.1	11.2
15	030	83.7	1	3.0	2	31.0	3	31.0	1.0	3	1.0	3	1.0	1.0	23.6
16	031	89.1	1	3.6	2	31.9	3	31.9	1.9	3	1.9	3	1.9	1.9	36.0
17	032	94.5	1	4.3	2	32.8	3	32.8	2.8	3	2.8	3	2.8	2.8	48.5
18	033	99.8	1	5.0	2	33.7	3	33.7	3.7	3	3.7	3	3.7	3.7	60.9
19	034	05.2	2	5.7	2	34.6	3	34.6	4.6	3	4.6	3	4.6	4.6	73.3
20	035	10.6	2	6.3	2	35.5	3	35.5	5.5	3	5.5	3	5.5	5.5	85.8
21	036	16.0	2	7	2	36.5	3	36.5	6.5	3	6.5	3	6.5	6.5	98.2

Source: Data Processing Result

Furthermore, the results of the number of clean water needs in table 4.19 above are multiplied by water needs at normal hours, namely 1 hour, the water demand factor at maximum hours is 1.15 and at peak hours is 1.75 (Criteria Dijend. Ciptakarya 2017)

**Tabel 20. Water demand fluctuation**

Factor	TAHUN PROYEKSI 2016-2036																					
	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	
Normal (L/det)	252	262,9	274,32	286	298	310,3	322,802	335,6	348,8	362,3	376,13	386,31	398,74	411,17	423,60	436,04	448,47	460,90	473,33	485,77	498,20	
FHM (L/det)	1,15	289,4	302,3	315,5	328,9	342,7	356,8	371,2	386,0	401,1	416,6	432,5	444,3	458,5	472,8	487,1	501,4	515,7	530,0	544,3	558,6	572,9
FJP (L/det)	1,75	440,4	460,0	480,1	500,6	521,5	543,0	564,9	587,4	610,4	634,0	658,2	676,0	697,8	719,5	741,3	763,1	784,8	806,6	828,3	850,1	871,8

FHM = Water usage factor on maximum day

FJP factor = Water consumption factor at peak hours

The results of data analysis show that the production capacity of the PDAM is 39.2 liters/second with details from the calculation results of the projected water demand for the city of Tidore Islands for the next 20 years, for normal use it is 488.20 liters/second, for a maximum of 572 days. .90 liters/second and for peak hours of 871.8 liters/second.

**DAFTAR PUSTAKA**

Azarella, L.A. <https://www.kompas.com/tren/read/2020/10/04/123000765/tanpa-makan-dan-minum-berapa-lama-manusia-bisa-bertahan-hidup-?page=all>.

BPS Jakarta, *Pedoman Penghitungan proyeksi penduduk dan lapangan kerja*, Jakarta-Indonesia

BPS Kota Tidore kepulauan. (2020). *Kecamatan Tidore Dalam Angka*,

Egodawatta, M. Haque, P. and A. Rahman. (2015). “Assessing the significance of climate and community factors on urban water demand,” *Int. J. Sustain. Built Environ.*, vol. 4, no. 2, pp. 222–230, , doi: 10.1016/j.ijsbe.2015.11.001.

Kementerian pekerjaan umum dan perumahan rakyat direktorat jenderal cipta karya. (2017). *Laporan Kinerja*

Kurniawan, M. A. H. Fitriani, and F. Hadinata.(2021). “Analisis Kebutuhan Penyediaan Air Bersih di Kota Palembang Analysis of Water Demand Supply in Palembang City,” doi: 10.25299/saintis2021.vol21(02).7611.

Maria, G. and M. Elisa, “A multi-criteria decision making approach to balance water supply-demand strategies in water supply systems,” vol. 5411, 2018, doi: 10.1590/0103-6513.20170062.

Tambunan, A. Putra, M. F. Teknik. D. T. Mesin, and U. S. Utara, “Analisis Kebutuhan Air Bersih Dari Perusahaan Daerah Air Minum ( Pdam ) Untuk Kelurahan Sei Agul 5 Tahun,” no. 120401083.

Quesnel, K. J. and N. K. Ajami. (2017). “Changes in water consumption linked to heavy news media coverage of extreme climatic events,” no. October, pp. 1–9.